

Rupert Country Club

PLAN SET OCT 23RD 2020

FULL HEAD COUNT = 451

PART CIRCLE COUNT = 62

LATERAL ISOLATION AQUA-FUSE 360 2" VALVE = 108

6 AQUA SADDLES ON 8" / 83 AQUA SADDLES ON 6" 169 END OF LINE UNITS

QUICK COUPLER NOT ON PLAN = 0

CONTROLLER 64 STATION = 9

CONTROLLER PADS = 9

EXISTING WEE-LINKS CONTROLLER TO BE TIED IN WITH NEW POWER COM WIRE

AIR RELIEF VALVES = 1 USE 1/4" LATERAL ISOLATION VALVE

EXTRA WIRE DROPS PER PLAN = 0

POWER TRAY CABLE #8 = 2,865 PER PLAN (SAME)

POWER TRAY CABLE #10 = 5,900 PER PLAN (SAME)

COMMUNICATION WIRE PER PLAN = 8,800 LN. FT. (SAME)

HDPE-11.0-4710-2" LATERAL LINE = 29,500 PER PLAN

HDPE-13.5-4710-6" MAIN LINE = 1,950 LN. FT. PER PLAN

HDPE-13.5-4710-8" MAIN LINE = 2350 LN. FT. PER PLAN

HDPE-13.5-4710-10" MAIN LINE = 400 LN. FT. PER PLAN

Prelim V.E. JR.



GOLF AS-BUILT DESIGN

LIMITED LIABILITY COMPANY

Jim Ruelle

G.P.S. Golf As-Built Design I.L.C.

1547 East Fort Road

Park City, Utah 84098

Tel: 801.557.9021

Email: As-Built@msn.com

6 - 6" MJ-MAIN LINE GATE VALVES (NO FLANGED VALVES)
 2 - 8" MJ-MAIN LINE GATE VALVES (NO FLANGED VALVES)
 0 - 10" MJ-MAIN LINE GATE VALVES (NO FLANGED VALVES) REMOVED 2
 1 - 4" MJ-MAIN LINE GATE VALVES (NO FLANGED VALVES) WEE-LINKS

Prints on 24" by 30" @ 100 Scale

9 Hr Watering Window = 650 gpm @ .29 inches per night = 300,000 gpm /pnight

Peak Summer Watering needs @ .29

